



MUNICIPAL CORPORATION CHANDIGARH
Public Health Laboratory at Water Works Sector 39.

TEST - REPORT

Not for legal use


Ref. No. & Date : - No.885/PS/23 Dated 25.05.2023
Issued to : - The Principal,
D.A.V Public School,
Sector -8 - C, Chandigarh.
Quantity of sample : - Approximate 1200 ml.
Date of Collection : - 26.05.2023
Client reference : - Sample collected by Laboratory Staff
Packing of sample : - Sample filled in P.P. and Glass Bottle.
Source of sample :- from School Tap of D.A.V Public School,
Sector - 8 - C, Chandigarh.


S. No.	Examination	Quality Standard	Units	Results
1.	Turbidity	<1.0	N.T.U	0.8
2.	pH	7.0-8.5	----	7.76
3.	Residual Chlorine	0.2 - 0.4	mg/l.	0.2
4.	Total Alkalinity (as CaCO ₃)	200	-do-	94
5.	Total Hardness (as CaCO ₃)	200	-do-	76
6.	Chlorides (as Cl)	200	-do-	04
7.	Free & Saline Ammonia	Nil	-do-	NIL
8.	Total Dissolved Solids	500	-do-	135
9.	M.P.N. of Coliform Bacilli per 100ml of water	Zero	M.P.N.	0 (Excellent)

Payment received vide Receipt No.05/2023-24/136760, date: 25.05.2023 Amount Rs.3300 -.

Note:- **Water is fit for drinking.**

Lab. No. MCPHL/23/ 2277
Dated: - 29.05.2023



Chemist,
MCPH Laboratory,
Chandigarh



Sub Divisional Engineer,
M.C.P.H. Sub Division No. 1,
Chandigarh

Endst No. MCPHL/23/ _____

Dated _____

Copy forwarded to the Medical Officer of Health, Municipal Corporation, Sector-17, Chandigarh for information please.


Chemist
MCPH Laboratory
Chandigarh


Sub Divisional Engineer,
M.C.P.H. Sub Division No. 1,
Chandigarh